

Gas Service/Breakdown Record

Certificate Ref.

84 Main Road 3

Certificate No 84 Main Road 3

Installation Details

Installation Address: HANNAH THORPE
84 MAIN ROAD
Meriden
Postcode: CV7 7NF

Client Details

Client Address: HANNAH THORPE
84 MAIN ROAD
Meriden
Postcode: CV7 7NF

Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: N/A CO2 Reading: 9.5 % CO Reading: 50 ppm

Boiler Make: Ideal Boiler Model: LOGIC COMBI 35 Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory YES NO NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

cleaned condense trap and serviced boiler

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 10:33 am
Gas ID Number 4464997 Time of Departure: 10:33 am
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Wed-21-Dec-2022
Report Received By Name: Signature: Date: Wed-21-Dec-2022