

# Gas Service/Breakdown Record

Certificate Ref.

69b Waverley Road Leamington Spa

Certificate No 69b Waverley Road L

## Installation Details

Installation Address: Sylwia Kola  
69b Waverley Road Leamington Spa CV31 2DE  
Leamington Spa

Postcode: CV31 2DE

## Client Details

Client Address: Sylwia Kola  
69b Waverley Road Leamington Spa CV31 2DE  
Leamington Spa

Postcode: CV31 2DE

## Appliance Details

CO/CO2 Ratio: 0.0010 Service: YES Breakdown: YES CO2 Reading: 9.0 % CO Reading: 90 ppm

Boiler Make: Baxi Boiler Model: Duo tec 24 HEA GC no 47-075 Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

| Preliminary Checks                                     | Satisfactory | YES | NO | NA |
|--------------------------------------------------------|--------------|-----|----|----|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES          |     |    |    |
| Ventilation Size/H-L                                   | YES          |     |    |    |
| Water/Fuel - Sound                                     | YES          |     |    |    |
| Electrically Fused                                     | YES          |     |    |    |
| Correct Valving Arrangement                            | YES          |     |    |    |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES          |     |    |    |
| Boiler/Plant room Clean & Clear                        | YES          |     |    |    |
| Service Checks                                         | Satisfactory | YES | NO | NA |
| Heat Exchanger                                         | YES          |     |    |    |
| Ignition                                               | YES          |     |    |    |
| Gas Valve                                              | YES          |     |    |    |
| Fan                                                    | YES          |     |    |    |
| Safety Device                                          | YES          |     |    |    |
| Control Box                                            | YES          |     |    |    |
| Burner & Pilot                                         | YES          |     |    |    |
| Fuel Pressure & Type                                   | YES          |     |    |    |
| Service Operations                                     | Satisfactory | YES | NO | NA |
| Burner Washed & Clean                                  |              |     |    |    |
| Pilot Assembly Cleaned & Adjusted                      |              |     |    |    |
| Ignition System Cleaned & Adjusted                     |              |     |    |    |
| Burner Fan & Airways Cleaned                           |              |     |    |    |
| Heat Exchanger/Flueways Clean & Clear                  |              |     |    | NA |
| Fuel & Electrical Supply Connected & Sound             | YES          |     |    |    |
| Interlocks in Place                                    |              |     |    |    |

## Additional Notes

cleaned condense trap and serviced boiler

## Spares Required

none

## Engineers Details

Trading Title: Coventry Gas Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 10:06 am

Gas ID Number: 4464997 Time of Departure: 10:06 am

Telephone Number: 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Mon-17-Oct-2022

Report Received By Name: Andrew King-Page Signature: Date: Mon-17-Oct-2022