

# Gas Service/Breakdown Record

Certificate Ref.

4 Wheatcroft Close 2

Certificate No 4 Wheatcroft Close 2

## Installation Details

Installation Address: Stuart cross  
4 wheatcroft close ☐ Redditch ☐ B97  
Redditch

Postcode: B97 6UL

## Client Details

Client Address: Stuart cross  
4 wheatcroft close Redditch B97  
Redditch

Postcode: B97 6UL

## Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: N/A CO2 Reading: 9.47 % CO Reading: 45 ppm

Boiler Make: ALPHA Boiler Model: E Tec Plus 38 Boiler Serial No:   
Appliance Make: Appliance Model: Appliance Serial No:

## Preliminary Checks

### Satisfactory

YES

NO

NA

|                                                        |     |  |  |
|--------------------------------------------------------|-----|--|--|
| Flue: Atmospheric/Fan assisted/Fan Dilution            | YES |  |  |
| Ventilation Size/H-L                                   | YES |  |  |
| Water/Fuel - Sound                                     | YES |  |  |
| Electrically Fused                                     | YES |  |  |
| Correct Valving Arrangement                            | YES |  |  |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |  |  |
| Boiler/Plant room Clean & Clear                        | YES |  |  |

## Service Checks

### Satisfactory

|                      |     |  |  |
|----------------------|-----|--|--|
| Heat Exchanger       | YES |  |  |
| Ignition             | YES |  |  |
| Gas Valve            | YES |  |  |
| Fan                  | YES |  |  |
| Safety Device        | YES |  |  |
| Control Box          | YES |  |  |
| Burner & Pilot       | YES |  |  |
| Fuel Pressure & Type | YES |  |  |

## Service Operations

### Satisfactory

|                                            |     |  |    |
|--------------------------------------------|-----|--|----|
| Burner Washed & Clean                      |     |  |    |
| Pilot Assembly Cleaned & Adjusted          |     |  |    |
| Ignition System Cleaned & Adjusted         |     |  |    |
| Burner Fan & Airways Cleaned               |     |  |    |
| Heat Exchanger/Flueways Clean & Clear      |     |  | NA |
| Fuel & Electrical Supply Connected & Sound | YES |  |    |
| Interlocks in Place                        |     |  |    |

## Additional Notes

cleaned condense trap and filter, serviced boiler

## Spares Required

none

## Engineers Details

Trading Title: Coventry Gas Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 02:13 pm  
Gas ID Number 4464997 Time of Departure: 02:13 pm  
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Tue-04-Oct-2022  
Report Received By Name: Signature: Date: Tue-04-Oct-2022