

# Gas Service/Breakdown Record

Certificate Ref.

32 Gilbert Road 3

Certificate No 32 Gilbert Road 3

## Installation Details

Installation Address: Avi Virdi  
32 Gilbert Road  
Smethwick

Postcode: B66 4PY

## Client Details

Client Address: Avi Virdi  
32 Gilbert Road  
Smethwick

Postcode: B66 4PY

## Appliance Details

CO/CO2 Ratio:

0.0009

Service:

YES

Breakdown:

N/A

CO2 Reading:

10.0 %

CO Reading:

92 ppm

Boiler Make: Worcester Boiler Model: Greenstar 27CDi Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

## Preliminary Checks

Satisfactory

YES

NO

NA

|                                                        |     |  |  |
|--------------------------------------------------------|-----|--|--|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES |  |  |
| Ventilation Size/H-L                                   | YES |  |  |
| Water/Fuel - Sound                                     | YES |  |  |
| Electrically Fused                                     | YES |  |  |
| Correct Valving Arrangement                            | YES |  |  |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |  |  |
| Boiler/Plant room Clean & Clear                        | YES |  |  |

## Service Checks

Satisfactory

|                      |     |  |  |
|----------------------|-----|--|--|
| Heat Exchanger       | YES |  |  |
| Ignition             | YES |  |  |
| Gas Valve            | YES |  |  |
| Fan                  | YES |  |  |
| Safety Device        | YES |  |  |
| Control Box          | YES |  |  |
| Burner & Pilot       | YES |  |  |
| Fuel Pressure & Type | YES |  |  |

## Service Operations

Satisfactory

|                                            |     |  |    |
|--------------------------------------------|-----|--|----|
| Burner Washed & Clean                      |     |  |    |
| Pilot Assembly Cleaned & Adjusted          |     |  |    |
| Ignition System Cleaned & Adjusted         |     |  |    |
| Burner Fan & Airways Cleaned               |     |  |    |
| Heat Exchanger/Flueways Clean & Clear      |     |  | NA |
| Fuel & Electrical Supply Connected & Sound | YES |  |    |
| Interlocks in Place                        |     |  |    |

## Additional Notes

cleaned condense trap and serviced boiler

## Spares Required

none

## Engineers Details

Trading Title: Coventry Gas Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

10:36 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

10:36 am

Report Issued By Name: Andrew King-Page

Signature:

Date: Mon-26-Sept-2022

Report Received By Name: Andrew King-Page

Signature:

Date: Mon-26-Sept-2022