

Gas Service/Breakdown Record

Certificate Ref.

30 Aboyne Close 2

Certificate No 30 Aboyne Close 2

Installation Details

Installation Address: Peter Stephenson
30 Aboyne Close
Birmingham

Postcode: B5 7PQ

Client Details

Client Address: Peter Stephenson
30 Aboyne Close
Birmingham

Postcode: B5 7PQ

Appliance Details

CO/CO2 Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2 Reading:

45 %

CO Reading:

9.05 ppm

Boiler Make: Worcester

Boiler Model: Greenstar 24i Junior

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

09:41 am

Gas ID Number

4464997

Time of Departure:

09:41 am

Telephone Number

07961768920

Report Issued By Name: Andrew King-Page

Signature:

Date: Thu-25-Aug-2022

Report Received By Name:

Signature:

Date: Thu-25-Aug-2022