

# Gas Service/Breakdown Record

Certificate Ref.

3 Leam Street 2

Certificate No 3 Leam Street 2

## Installation Details

Installation Address: Val Hollier  
3 Leam Street  
Leamington Spa

Postcode: CV31 1DZ

## Client Details

Client Address: Val Hollier  
3 Leam Street  
Leamington Spa

Postcode: CV31 1DZ

## Appliance Details

CO/CO2 Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.05 %

CO Reading:

90 ppm

Boiler Make: Worcester

Boiler Model: Greenstar 30i Erp

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

## Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean &amp; Clear

YES

## Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner &amp; Pilot

YES

Fuel Pressure &amp; Type

YES

## Service Operations

Satisfactory

Burner Washed &amp; Clean

Pilot Assembly Cleaned &amp; Adjusted

Ignition System Cleaned &amp; Adjusted

Burner Fan &amp; Airways Cleaned

Heat Exchanger/Flueways Clean &amp; Clear

NA

Fuel &amp; Electrical Supply Connected &amp; Sound

YES

Interlocks in Place

## Additional Notes

cleaned filter and condense trap

## Spares Required

none

## Engineers Details

Trading Title: Coventry Gas Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

09:03 am

Gas ID Number

4464997

Time of Departure:

09:03 am

Telephone Number

07961768920

Report Issued By Name: Andrew King-Page

Signature:

Date:

Tue-02-Aug-2022

Report Received By Name:

Signature:

Date:

Tue-02-Aug-2022