

Gas Service/Breakdown Record

Certificate Ref. The Oaks Five Ways Road Hatton C
 Certificate No The Oaks Five Ways I

Installation Details

Installation Address: Kate Parkinson
The Oaks
Five Ways Road
Hatton
 Postcode: CV35 7JB

Client Details

Client Address: Kate Parkinson
The Oaks
Five Ways Road
Hatton
 Postcode: CV35 7JB

Appliance Details

CO/CO2 Ratio: 0.0005 Service: 0.0005 Breakdown: N/A CO2 Reading: 47 % CO Reading: 9.45 ppm
 Boiler Make: Ideal Boiler Model: ICOS SYSTEM HE24 Boiler Serial No:
 Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution		YES		
Ventilation Size/H-L		YES		
Water/Fuel - Sound		YES		
Electrically Fused		YES		
Correct Valving Arrangement		YES		
Isolation Available - Electrical/Fuel (Within 1 metre)		YES		
Boiler/Plant room Clean & Clear		YES		
Service Checks	Satisfactory			
Heat Exchanger		YES		
Ignition		YES		
Gas Valve		YES		
Fan		YES		
Safety Device		YES		
Control Box		YES		
Burner & Pilot		YES		
Fuel Pressure & Type		YES		
Service Operations	Satisfactory			
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound		YES		
Interlocks in Place				

Additional Notes
 cleaned out sump and condense trap

Spares Required

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
 Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 10:40 am
 Gas ID Number 4464997 Time of Departure: 10:40 am
 Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature:  Date: Mon-01-Aug-2022
 Report Received By Name: Signature: Date: Mon-01-Aug-2022