

Gas Service/Breakdown Record

Certificate Ref.

29 Griffin Road Serv

Certificate No 29 Griffin Road

Installation Details

Installation Address: Ann Mucklow
29
Griffin Rd
Warwick
Postcode: CV34 6QX

Client Details

Client Address: Ann Mucklow
29
Griffin Rd
Warwick
Postcode: CV34 6QX

Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: N/A CO2 Reading: 8.6 % CO Reading: 40 ppm

Boiler Make: Worcester Boiler Model: Greenstar 30 Cdi Cla Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear	YES		
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place	YES		

Additional Notes

system filter cleaned and condense trap cleared of debris

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden
Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 09:37 am
Gas ID Number N/A Time of Departure: 09:37 am
Telephone Number 07502848685

Report Issued By Name: Steve Owen Signature: Date: Fri-08-Jul-2022
Report Received By Name: Signature: Date: Fri-08-Jul-2022