

Gas Service/Breakdown Record

Certificate Ref.

16b Heath Way Serv

Certificate No 16b Heath Way

Installation Details

Installation Address:

Harvey Selwyn
16B Heath Way
Rugby

Postcode: CV22 5JA

Client Details

Client Address:

Harvey Selwyn
16B Heath Way
Rugby

Postcode: CV22 5JA

Appliance Details

CO/CO2 Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2 Reading:

8.4 %

CO Reading:

87 ppm

Boiler Make:

Baxi

Boiler Model:

836

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

YES

Additional Notes

condense trap cleaned of debris. system filter also cleaned

Spares Required

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

09:51 am

Gas ID Number

N/A

Time of

Telephone Number

07502848685

Departure:

09:51 am

Report Issued By

Name:

Steve Owen

Signature:

Date:

Mon-04-Jul-2022

Report Received By

Name:

Signature:

Date:

Mon-04-Jul-2022