

Gas Service/Breakdown Record

Certificate Ref.

4 Pewter Court Serv

Certificate No 4 Pewter Court

Installation Details

Installation Address: Jon Cater
4 Pewter Court
Wilncote
Tamworth
Postcode: B775FX

Client Details

Client Address: Jon Cater
4 Pewter Court
Wilncote
Tamworth
Postcode: B775FX

Appliance Details

CO/CO2 Ratio: 0.0037 Service: YES Breakdown: N/A CO2 Reading: 1.6 % CO Reading: 60 ppm

Boiler Make: Baxi Boiler Model: Megaflo 2 System 24 Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place	YES		

Additional Notes

condense trap cleared of debris

Spares Required

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden
Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 05:09 pm
Gas ID Number: N/A Time of Departure: 05:09 pm
Telephone Number: 07502848685

Report Issued By Name: Steve Owen Signature: Date: Mon-20-Jun-2022

Report Received By Name: Signature: Date: Mon-20-Jun-2022