

Gas Service/Breakdown Record

Certificate Ref.

363 Lentons Lane Serv

Certificate No 363 Lentons Lane

Installation Details

Installation Address:

363 Lentons Lane
Coventry

Postcode: CV2 1AA

Client Details

Client Address:

H2L Lettings
38 Main Road
Meriden

Postcode: CV7 7NF

Appliance Details

CO/CO2 Ratio:

0.0008

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.0 %

CO Reading:

69 ppm

Boiler Make:

Baxi

Boiler Model:

424 Combi

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)			NO	
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned	YES			
Heat Exchanger/Flueways Clean & Clear	YES			
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place	YES			

Additional Notes

PRV connection weeping

Spares Required

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

11:23 am

Gas ID Number

N/A

Time of Departure:

11:23 am

Telephone Number

07502848685

Report Issued By Name:

Steve Owen

Signature:

Date:

Thu-16-Jun-2022

Report Received By Name:

Signature:

Date:

Thu-16-Jun-2022