

Gas Service/Breakdown Record

Certificate Ref.

4 Hayward Close Serv

Certificate No 4 Hayward Close

Installation Details

Installation Address: David Williams
4 Hayward Close
Hampton Magna

Postcode: CV35 8TJ

Client Details

Client Address: David Williams
4 Hayward Close
Hampton Magna

Postcode: CV35 8TJ

Appliance Details

CO/CO2 Ratio:

0.0011

Service:

YES

Breakdown:

N/A

CO2 Reading:

7.7 %

CO Reading:

87 ppm

Boiler Make:

Baxi

Boiler Model:

830

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

YES

Additional Notes

condense trap cleared of debris. system filter cleaned

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

11:21 am

Gas ID Number

N/A

Time of

Telephone Number

07502848685

Departure:

11:21 am

Report Issued By

Name:

Steve Owen

Signature:

Date:

Wed-15-Jun-2022

Report Received By

Name:

Signature:

Date:

Wed-15-Jun-2022