

Gas Service/Breakdown Record

Certificate Ref.

46 Blythswood Road Serv

Certificate No 45 Blythswood Road 5

Installation Details

Installation Address: 46 Blythswood Road Tyseley

Postcode: B11 2BU

Client Details

Client Address: Black And Golds Estate Agents
117 Stratford Rd
Shirley
Solihull

Postcode: B90 3ND

Appliance Details

CO/CO2 Ratio: 0.0004 Service: YES Breakdown: N/A CO2 Reading: 8.8 % CO Reading: 38 ppm

Boiler Make: Glowworm Boiler Model: Easicom 24c Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution			
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks

Satisfactory	YES	NO	NA
Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory	YES	NO	NA
Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear	YES		
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place	YES		

Additional Notes

Condense trap cleared of debris

Spares Required

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden

Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 10:38 am

Gas ID Number: N/A Time of Departure: 10:38 am

Telephone Number: 07502848685

Report Issued By Name: Steve Owen Signature: Date: Tue-07-Jun-2022

Report Received By Name: Signature: Date: Tue-07-Jun-2022