

Gas Service/Breakdown Record

Certificate Ref.

188 Emscote Road Gs

Certificate No 188 Emscote Road Gs

Installation Details

Installation Address: Stuart Cole
188 Emscote Road
Warwick
Postcode: CV34 5QN

Client Details

Client Address: Stuart Cole
188 Emscote Road
Warwick
Postcode: CV34 5QN

Appliance Details

CO/CO2 Ratio: 0.0008 Service: YES Breakdown: N/A CO2 Reading: 9.6 % CO Reading: 75 ppm

Boiler Make: Worcester Boiler Model: Greenstar 25i Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks

Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear			

Service Checks

Satisfactory	YES	NO	NA
Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations

Satisfactory	YES	NO	NA
Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear	YES		
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place	YES		

Additional Notes

condense trap cleared of debris. system filter cleaned

Spares Required

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden
Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 01:21 pm
Gas ID Number: N/A Time of Departure: 01:21 pm
Telephone Number: 07502848685

Report Issued By Name: Steve Owen Signature: Date: Tue-07-Jun-2022

Report Received By Name: Signature: Date: Tue-07-Jun-2022