



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

250 Pool Farm Road Serv

Certificate No 250 Pool Farm Road 3

Installation Details

Installation
Address:250 Pool Farm Road
Acocks Green

Postcode: B27 7EU

Client Details

Client
Address:Black And Golds Estate Agents
117 Stratford Rd
Shirley
Solihull

Postcode: B90 3ND

Appliance Details

CO/CO2
Ratio:

0.0003

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.0 %

CO Reading:

25 ppm

Boiler Make:

Intergas

Boiler Model:

Rapid 25

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

YES

Additional Notes

condense trap cleared of debris

Spares Required

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

11:35 am

Gas ID Number

N/A

Time of

Departure:

11:35 am

Telephone Number

07502848685

Report Issued By

Name:

Steve Owen

Signature:

Report Received By

Name:

Signature:

Date:

Tue-07-Jun-2022

Date:

Tue-07-Jun-2022