

Gas Service/Breakdown Record

Certificate Ref.

7 Rich Close-Stuart Cole-26May2022

Certificate No 7 Rich Close Serv

Installation Details

Installation Address: 7 Rich Close
Warwick
Warwickshire
Postcode: CV344QH

Client Details

Client Address: Stuart Cole
188 Emscote Road
Warwick
Postcode: CV34 5QN

Appliance Details

CO/CO2 Ratio: 0.0010 Service: YES Breakdown: N/A CO2 Reading: 9.8 % CO Reading: 99 ppm
Boiler Make: Worcester Boiler Model: Greenstar 30i Combi Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear	YES			
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place	YES			

Additional Notes

condense trap and system filter cleaned

Spares Required

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden
Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 03:06 pm
Gas ID Number N/A Time of Departure: 03:06 pm
Telephone Number 07502848685

Report Issued By Name: Steve Owen Signature: Date: Thu-26-May-2022
Report Received By Name: Signature: Date: Thu-26-May-2022