



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

14 Lower Ladyes Hill Serv

Certificate No 14 Lower Ladyes Hill :

Installation Details

Installation
Address:Tania Martin
14 Lower Ladyes Hill
Kenilworth
Warwickshire

Postcode: CV8 2GN

Client Details

Client
Address:Tania Martin
14 Lower Ladyes Hill
Kenilworth
Warwickshire

Postcode: CV8 2GN

Appliance Details

CO/CO2
Ratio:

Service:

Breakdown:

N/A

CO2

Reading:

8.6 %

CO Reading:

16 ppm

Boiler Make:

Main

Boiler Model:

main combi 25 eco

Boiler Serial No:

143940070

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

YES

Additional Notes

Spares Required

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

10:04 am

Gas ID Number

N/A

Time of

Telephone Number

07502848685

Departure:

10:04 am

Report Issued By

Name:

Steve Owen

Signature:

Date:

Fri-13-May-2022

Report Received By

Name:

Signature:

Date:

Fri-13-May-2022