



West Lothian Gas



## Gas Service/Breakdown Record

Certificate Ref.

6 Warren Drive

Certificate No 6 Warren Drive Serv

## Installation Details

Installation  
Address:Mrs Amanda Pemberton  
6 Warren Drive  
Dorridge  
Solihull

Postcode: B938JY

## Client Details

Client  
Address:Mrs Amanda Pemberton  
6 Warren Drive  
Dorridge  
Solihull

Postcode: B938JY

## Appliance Details

CO/CO2  
Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2

Reading:

8.4 %

CO Reading:

41 ppm

Boiler Make:

Baxi

Boiler Model:

Megaflo 32 System

Boiler Serial No:

204870020

Appliance Make:

Appliance Model:

Appliance Serial No:

## Preliminary Checks

## Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean &amp; Clear

YES

## Service Checks

## Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner &amp; Pilot

YES

Fuel Pressure &amp; Type

YES

## Service Operations

## Satisfactory

Burner Washed &amp; Clean

Pilot Assembly Cleaned &amp; Adjusted

Ignition System Cleaned &amp; Adjusted

Burner Fan &amp; Airways Cleaned

Heat Exchanger/Flueways Clean &amp; Clear

YES

Fuel &amp; Electrical Supply Connected &amp; Sound

YES

Interlocks in Place

YES

## Additional Notes

Trap cleaned

## Spares Required

## Engineers Details

Trading Title:

Coventry Gas Ltd  
47 Alspath Road  
Meriden  
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of  
Arrival:

11:29 am

Gas ID Number

N/A

Time of

Telephone Number

07502848685

Departure:

11:29 am

Report Issued By

Name:

Steve Owen

Signature:

Date:

Fri-13-May-2022

Report Received By

Name:

Signature:

Date:

Fri-13-May-2022