



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

6 Hampdon Way-Ciaran Whyte -08/

Certificate No 6 Hampdon Way

Installation Details

Installation
Address:Ciaran Whyte
6 Hampdon Way
Wellesbourne
Warwickshire

Postcode: CV35 9NX

Client Details

Client
Address:Ciaran Whyte
6 Hampdon Way
Wellesbourne

Postcode: CV35 9NX

Appliance Details

CO/CO2
Ratio:

0.0009

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.1 %

CO Reading:

86 ppm

Boiler Make:

Boiler Model:

Boiler Serial No:

Appliance Make:

Worcester

Appliance Model:

Worcester

Appliance Serial No:

550720000039773360

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

Worcester

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

YES

Additional Notes

Spares Required

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

04:18 pm

Gas ID Number

N/A

Time of

Telephone Number

07502848685

Departure:

04:18 pm

Report Issued By

Name:

Steve Owen

Signature:

Date:

Fri-08-Apr-2022

Report Received By

Name:

Signature:

Date:

Fri-08-Apr-2022