



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

25 Frobisher Road Coventry CV3 6LW

Certificate No 25 Frobisher Road Co

Installation Details

Installation
Address:Paul Pavlou
25 Frobisher Road
Coventry

Postcode: CV3 6LW

Client Details

Client
Address:Paul Pavlou
25 Frobisher Road
Coventry

Postcode: CV3 6LW

Appliance Details

CO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.47 %

CO Reading:

45 ppm

Boiler Make:

Vaillant

Boiler Model:

ECOTEC PLUS 831 VUW 314

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned filter, repaired leak on filter, replaced diverter valve and serviced boiler

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

12:08 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

12:08 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Mon-04-Apr-2022

Report Received By

Name:

Signature:

Date:

Mon-04-Apr-2022