

# Gas Service/Breakdown Record

Certificate Ref.

36 Brentwood Avenue

Certificate No 36 Brentwood Avenue

## Installation Details

Installation Address: Gary Roberts  
36 Brentwood Ave  
Coventry  
Postcode: CV3 6FL

## Client Details

Client Address: Gary Roberts  
36 Brentwood Ave  
Coventry  
Postcode: CV3 6FL

## Appliance Details

CO/CO2 Ratio: 0.0007 Service: YES Breakdown: N/A CO2 Reading: 8.8 % CO Reading: 65 ppm

Boiler Make: Baxi Boiler Model: 830 Combi Boiler Serial No:  
Appliance Make: Appliance Model: Appliance Serial No:

## Preliminary Checks

Satisfactory YES NO NA

|                                                        |     |  |  |
|--------------------------------------------------------|-----|--|--|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES |  |  |
| Ventilation Size/H-L                                   | YES |  |  |
| Water/Fuel - Sound                                     | YES |  |  |
| Electrically Fused                                     | YES |  |  |
| Correct Valving Arrangement                            | YES |  |  |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |  |  |
| Boiler/Plant room Clean & Clear                        | YES |  |  |

## Service Checks

Satisfactory

|                      |     |  |  |
|----------------------|-----|--|--|
| Heat Exchanger       | YES |  |  |
| Ignition             | YES |  |  |
| Gas Valve            | YES |  |  |
| Fan                  | YES |  |  |
| Safety Device        | YES |  |  |
| Control Box          | YES |  |  |
| Burner & Pilot       | YES |  |  |
| Fuel Pressure & Type | YES |  |  |

## Service Operations

Satisfactory

|                                            |     |  |    |
|--------------------------------------------|-----|--|----|
| Burner Washed & Clean                      |     |  |    |
| Pilot Assembly Cleaned & Adjusted          |     |  |    |
| Ignition System Cleaned & Adjusted         |     |  |    |
| Burner Fan & Airways Cleaned               |     |  |    |
| Heat Exchanger/Flueways Clean & Clear      |     |  | NA |
| Fuel & Electrical Supply Connected & Sound | YES |  |    |
| Interlocks in Place                        |     |  |    |

## Additional Notes

cleaned condense trap and filter

## Spares Required

none

## Engineers Details

Trading Title: Coventry Gas Ltd  
47 Alspath Road  
Meriden  
Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 12:22 pm  
Gas ID Number: 4464997 Time of Departure: 12:22 pm  
Telephone Number: 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Mon-31-Jan-2022  
Report Received By Name: Signature: Date: Mon-31-Jan-2022