

Gas Service/Breakdown Record

Certificate Ref.

43 Wellington Road 1

Certificate No 43 Wellington Road 1

Installation Details

Installation Address:	Marie Cheung 43 Wellington Road Lillington	Client Address:	Marie Cheung 43 Wellington Road Lillington
	Postcode: CV32 7PB		Postcode: CV32 7PB

Client Details

Appliance Details

CO/CO2 Ratio:	0.0010	Service:	YES	Breakdown:	N/A	CO2 Reading:	9.7 %	CO Reading:	95 ppm
Boiler Make:	Baxi	Boiler Model:	830 Combi	Boiler Serial No:					
Appliance Make:		Appliance Model:		Appliance Serial No:					

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned condense trap and filter

Spares Required

none

Engineers Details

Trading Title:	Coventry Gas Ltd 47 Alspath Road Meriden	Gas Safe Number	526645	Time of Arrival:	04:17 pm
	Postcode: CV7 7LU	Gas ID Number	4464997	Time of Departure:	04:17 pm
		Telephone Number	07961768920		
Report Issued By Name:	Andrew King-Page	Signature:		Date:	Fri-28-Jan-2022
Report Received By Name:		Signature:		Date:	Fri-28-Jan-2022