



West Lothian Gas



## Gas Service/Breakdown Record

Certificate Ref.

fair for you 1

Certificate No Fair For You 1

## Installation Details

Installation Address: fair for you  
Unit 8 Elm Court  
Meriden Business Park  
Copse Drive  
Postcode: CV5 9RG

## Client Details

Client Address: fair for you  
Unit 8 Elm Court  
Meriden Business Park  
Copse Drive  
Postcode: CV5 9RG

## Appliance Details

CO/CO2 Ratio: 0.0010 Service: YES Breakdown: N/A CO2 Reading: 9.35 % CO Reading: 93 ppm

Boiler Make: Worcester Boiler Model: Greenstar 25i ERP Boiler Serial No:  
Appliance Make: Appliance Model: Appliance Serial No:

## Preliminary Checks

Satisfactory YES NO NA

|                                                        |     |  |  |
|--------------------------------------------------------|-----|--|--|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES |  |  |
| Ventilation Size/H-L                                   | YES |  |  |
| Water/Fuel - Sound                                     | YES |  |  |
| Electrically Fused                                     | YES |  |  |
| Correct Valving Arrangement                            | YES |  |  |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |  |  |
| Boiler/Plant room Clean & Clear                        | YES |  |  |

## Service Checks

Satisfactory

|                      |     |  |  |
|----------------------|-----|--|--|
| Heat Exchanger       | YES |  |  |
| Ignition             | YES |  |  |
| Gas Valve            | YES |  |  |
| Fan                  | YES |  |  |
| Safety Device        | YES |  |  |
| Control Box          | YES |  |  |
| Burner & Pilot       | YES |  |  |
| Fuel Pressure & Type | YES |  |  |

## Service Operations

Satisfactory

|                                            |     |  |    |
|--------------------------------------------|-----|--|----|
| Burner Washed & Clean                      |     |  |    |
| Pilot Assembly Cleaned & Adjusted          |     |  |    |
| Ignition System Cleaned & Adjusted         |     |  |    |
| Burner Fan & Airways Cleaned               |     |  |    |
| Heat Exchanger/Flueways Clean & Clear      |     |  | NA |
| Fuel & Electrical Supply Connected & Sound | YES |  |    |
| Interlocks in Place                        |     |  |    |

## Additional Notes

cleaned condense trap and filter, serviced boiler

## Spares Required

none

## Engineers Details

Trading Title: Coventry Gas Ltd  
47 Alspath Road  
Meriden  
Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 09:47 am  
Gas ID Number 4464997 Time of Departure: 09:47 am  
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Wed-08-Dec-2021  
Report Received By Name: Signature: Date: Wed-08-Dec-2021