

Gas Service/Breakdown Record

Certificate Ref.

30 Kelvin Road Leamington CV32 7

Certificate No 30 Kelvin Road Leami

Installation Details

Installation Address: Mrs Surinder Ranautta
30 Kelvin Road
Leamington Spa
Postcode: CV32 7TE

Client Details

Client Address: Mrs Surinder Ranautta
30 Kelvin Road
Leamington Spa
Postcode: CV32 7TE

Appliance Details

CO/CO2 Ratio: 0.0005 Service: 0.0005 Breakdown: N/A CO2 Reading: 47 % CO Reading: 9.45 ppm

Boiler Make: Worcester Boiler Model: Greenstar 28CDi Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution		YES		
Ventilation Size/H-L		YES		
Water/Fuel - Sound		YES		
Electrically Fused		YES		
Correct Valving Arrangement		YES		
Isolation Available - Electrical/Fuel (Within 1 metre)		YES		
Boiler/Plant room Clean & Clear		YES		
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger		YES		
Ignition		YES		
Gas Valve		YES		
Fan		YES		
Safety Device		YES		
Control Box		YES		
Burner & Pilot		YES		
Fuel Pressure & Type		YES		
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound		YES		
Interlocks in Place				

Additional Notes

cleaned condense trap and filter, serviced boiler

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 09:50 am
Gas ID Number: 4464997 Time of Departure: 09:50 am
Telephone Number: 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Tue-16-Nov-2021
Report Received By Name: Signature: Date: Tue-16-Nov-2021