

Gas Service/Breakdown Record

Certificate Ref.

Westwood Heath

Certificate No Westwood Heath

Installation Details

Installation Address: 308 Westwood Heath Road, Coventry, CV4 8GP
308 Westwood Heath Road Coventry CV4 8GP

Postcode: CV4 8GP

Client Details

Client Address: H2L Lettings
38 Main Road
Meriden

Postcode: CV7 7NF

Appliance Details

CO/CO2 Ratio:

0.0005

Service: YES

Breakdown: N/A

CO2 Reading:

9.03 %

CO Reading: 38 ppm

Boiler Make:

Baxi

Boiler Model:

PLATINUM 40 HE GC NO 47-

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned condense trap and filter, serviced boiler

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

04:53 pm

Gas ID Number

4464997

Time of Departure:

04:53 pm

Telephone Number

07961768920

Report Issued By Name:

Andrew King-Page

Signature:



Date:

Thu-21-Oct-2021

Report Received By Name:

Signature:

Date:

Thu-21-Oct-2021