



West Lothian Gas



## Gas Service/Breakdown Record

Certificate Ref.

52 Wilsons lane Longford Coventry

Certificate No 52 Wilsons lane Longf

## Installation Details

Installation  
Address:Daniel Stevens  
52 Wilson's lane  
Longford  
Coventry

Postcode: CV6 6AD

## Client Details

Client  
Address:Daniel Stevens  
52 Wilson's lane  
Longford  
Coventry

Postcode: CV6 6AD

## Appliance Details

CO/CO2  
Ratio:

0.0005

Service:

YES

Breakdown:

YES

CO2

Reading:

9.45 %

CO Reading:

47 ppm

Boiler Make:

Main

Boiler Model:

main combi 25 eco

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

## Preliminary Checks

## Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean &amp; Clear

YES

## Service Checks

## Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner &amp; Pilot

YES

Fuel Pressure &amp; Type

YES

## Service Operations

## Satisfactory

Burner Washed &amp; Clean

Pilot Assembly Cleaned &amp; Adjusted

Ignition System Cleaned &amp; Adjusted

Burner Fan &amp; Airways Cleaned

Heat Exchanger/Flueways Clean &amp; Clear

NA

Fuel &amp; Electrical Supply Connected &amp; Sound

YES

Interlocks in Place

## Additional Notes

Serviced boiler

## Spares Required

none

## Engineers Details

Trading Title:

Coventry Gas Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of  
Arrival:

10:53 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

10:53 am

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Mon-27-Sep-2021

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Mon-27-Sep-2021