



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

30 Aboyne Close 1

Certificate No 30 Aboyne Close 1

Installation Details

Installation
Address:Peter Stephenson
30 Aboyne Close
Birmingham

Postcode: B5 7PQ

Client Details

Client
Address:Peter Stephenson
30 Aboyne Close
Birmingham

Postcode: B5 7PQ

Appliance Details

CO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2

Reading:

47 %

CO Reading:

9.45 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 24i Junior

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned filter and condense trap, filter should be on return to boiler, plate heat exchanger showing signs of blockages

Spares Required

New system filter and plate heat exchanger

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

11:14 am

Gas ID Number

4464997

Time of

Departure:

11:14 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Wed-08-Sep-2021

Report Received By

Name:

Signature:

Date:

Wed-08-Sep-2021