

Gas Service/Breakdown Record

Certificate Ref.

75 Ashford Gardens

Certificate No 75 Ashford Gardens

Installation Details

Installation Address:

Mr Singh
75 Ashford Gardens
Leamington Spa

Postcode: CV31 2NB

Client Details

Client Address:

Mr Singh
75 Ashford Gardens
Leamington Spa

Postcode: CV31 2NB

Appliance Details

CO/CO2 Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.01 %

CO Reading:

45 ppm

Boiler Make:

Glow worm

Boiler Model:

Ultracom 30cxi

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

boiler has no filter

Spares Required

advised landlord

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

10:58 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

10:58 am

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Mon-23-Aug-2021

Report Received By

Name:

Signature:

Date:

Mon-23-Aug-2021