



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

81 Shipston Road Se

Certificate No 81 Shipston Road Se

Installation Details

Installation
Address:81 Shipston Road
Stratford Upon Avon
Warwickshire

Postcode: CV37 7LW

Client Details

Client
Address:Three60 SolutionsCo Limited
12 Eastcotes,
Coventry

Postcode: CV4 9AU

Appliance Details

CO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

NO

CO2

Reading:

47 %

CO Reading:

9.45 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 28CDi

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

serviced boiler, boiler gas no scale filter or system filter

Spares Required

advised landlord

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

12:22 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

12:22 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Tue-10-Aug-2021

Report Received By

Name:

Signature:

Date:

Tue-10-Aug-2021