

Gas Service/Breakdown Record

Certificate Ref.

3 Leam Street 1

Certificate No 3 Leam Street 1

Installation Details

Installation Address: Val Hollier
3 Leam Street
Leamington Spa

Postcode: CV31 1DZ

Client Details

Client Address: Val Hollier
3 Leam Street
Leamington Spa

Postcode: CV31 1DZ

Appliance Details

CO/CO2 Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.56 %

CO Reading:

48 ppm

Boiler Make: Worcester

Boiler Model: Greenstar 30i Erp

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

10:15 am

Gas ID Number

4464997

Time of Departure:

10:15 am

Telephone Number

07961768920

Report Issued By Name: Andrew King-Page

Signature:

Date:

Fri-23-Jul-2021

Report Received By Name:

Signature:

Date:

Fri-23-Jul-2021