



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

2 Beauchamp Avenue 1

Certificate No 2 Beauchamp Avenue

Installation Details

Installation
Address:Rosalyn Kane
2 Beauchamp Avenue
Leamington Spa

Postcode: CV32 5TA

Client Details

Client
Address:Rosalyn Kane
2 Beauchamp Avenue
Leamington Spa

Postcode: CV32 5TA

Appliance Details

CO/CO2
Ratio:

0.0002

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.12 %

CO Reading:

23 ppm

Boiler Make:

Intergas

Boiler Model:

Compact Hre 30 Sb

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

required new spark generator, cleaned filter and condense trap

Spares Required

spark generator

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

02:26 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

02:26 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Mon-01-Feb-2021

Report Received By

Name:

Signature:

Date:

Mon-01-Feb-2021