



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

623 Kenilworth Road Balsall Comm

Certificate No 623 Kenilworth Road I

Installation Details

Installation
Address:Jamie Gaskin
623 Kenilworth Road
Balsall Common

Postcode: CV7 7DX

Client Details

Client
Address:Jamie Gaskin
623 Kenilworth Road
Balsall Common

Postcode: CV7 7DX

Appliance Details

CO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2

Reading:

8.95 %

CO Reading:

45 ppm

Boiler Make:

ALPHA

Boiler Model:

CD50

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

NO

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

NO

Pilot Assembly Cleaned & Adjusted

NO

Ignition System Cleaned & Adjusted

NO

Burner Fan & Airways Cleaned

NO

Heat Exchanger/Flueways Clean & Clear

NO

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

several leaks on boiler means unable to perform a full service on boiler as to do so would render the boiler unusable, all safety checks passed

Spares Required

boiler is beyond economical repair

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

12:23 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

12:23 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Wed-27-Jan-2021

Report Received By

Name:

Signature:

Date:

Wed-27-Jan-2021