

Gas Service/Breakdown Record

Certificate Ref.

7 Liveridge Close

Certificate No 7 Liveridge Close

Installation Details

Installation Address: Alan Perrigo
7 Liveridge Close
Henley In Arden

Postcode: B95 5FX

Client Details

Client Address: Alan Perrigo
7 Liveridge Close
Henley In Arden

Postcode: B95 5FX

Appliance Details

CO/CO2 Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.01 %

CO Reading:

45 ppm

Boiler Make:

Ideal

Boiler Model:

Logic Espi 30

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

cleaned condense trap and serviced boiler

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

09:51 am

Gas ID Number

4464997

Time of Departure:

09:51 am

Telephone Number

07961768920

Report Issued By Name:

Andrew King-Page

Signature:



Date:

Mon-18-Jan-2021

Report Received By Name:

Signature:

Date:

Mon-18-Jan-2021