

# Gas Service/Breakdown Record

Certificate Ref.

6 North Street Nuneaton CV10 8BL

Certificate No 6 North Street Nuneat

## Installation Details

Installation Address: Kevin Cleary  
6 North Street  
Nuneaton

Postcode: CV10 8BL

## Client Details

Client Address: Kevin Cleary  
6 North Street  
Nuneaton

Postcode: CV10 8BL

## Appliance Details

CO/CO2 Ratio: 0.0005 Service: YES Breakdown: NO CO2 Reading: 9.45 % CO Reading: 47 ppm

Boiler Make: Worcester Boiler Model: Greenstar 32CDi Comp Boiler Serial No:

Appliance Make: Appliance Model: Appliance Serial No:

## Preliminary Checks

| Satisfactory                                           | YES | NO | NA |
|--------------------------------------------------------|-----|----|----|
| Flue:Atmospheric/Fan assisted/Fan Dilution             | YES |    |    |
| Ventilation Size/H-L                                   | YES |    |    |
| Water/Fuel - Sound                                     | YES |    |    |
| Electrically Fused                                     | YES |    |    |
| Correct Valving Arrangement                            | YES |    |    |
| Isolation Available - Electrical/Fuel (Within 1 metre) | YES |    |    |
| Boiler/Plant room Clean & Clear                        | YES |    |    |

## Service Checks

| Satisfactory         | YES | NO | NA |
|----------------------|-----|----|----|
| Heat Exchanger       | YES |    |    |
| Ignition             | YES |    |    |
| Gas Valve            | YES |    |    |
| Fan                  | YES |    |    |
| Safety Device        | YES |    |    |
| Control Box          | YES |    |    |
| Burner & Pilot       | YES |    |    |
| Fuel Pressure & Type | YES |    |    |

## Service Operations

| Satisfactory                               | YES | NO | NA |
|--------------------------------------------|-----|----|----|
| Burner Washed & Clean                      |     |    |    |
| Pilot Assembly Cleaned & Adjusted          |     |    |    |
| Ignition System Cleaned & Adjusted         |     |    |    |
| Burner Fan & Airways Cleaned               |     |    |    |
| Heat Exchanger/Flueways Clean & Clear      |     |    | NA |
| Fuel & Electrical Supply Connected & Sound | YES |    |    |
| Interlocks in Place                        |     |    |    |

## Additional Notes

unable to clean filter due to no filter key present

## Spares Required

none

## Engineers Details

Trading Title: Coventry Gas Ltd  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number: 526645 Time of Arrival: 01:48 pm

Gas ID Number: 4464997 Time of Departure: 01:48 pm

Telephone Number: 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Mon-07-Dec-2020

Report Received By Name: Signature: Date: Mon-07-Dec-2020