



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

69b Waverley Road Leamington Spa

Certificate No 69b Waverley Road L

Installation Details

Installation Address: Sylwia Kola
69b Waverley Road Leamington Spa CV31 2DE
Leamington Spa

Postcode: CV31 2DE

Client Details

Client Address: Sylwia Kola
69b Waverley Road Leamington Spa CV31 2DE
Leamington Spa

Postcode: CV31 2DE

Appliance Details

CO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

YES

CO2

Reading:

9.45 %

CO Reading:

47 ppm

Boiler Make:

Baxi

Boiler Model:

Duo tec 24 HEA GC no 47-075

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned condense trap and serviced boiler

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

05:27 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

05:27 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Tue-24-Nov-2020

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Tue-24-Nov-2020