



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

11 Steeping Road Rugby CV23 9SS

Certificate No 11 Steeping Road Rugby

Installation Details

Installation
Address:Kevin McLoughlin
11 Steeping Road
Rugby

Postcode: CV239SS

Client Details

Client
Address:Kevin McLoughlin
11 Steeping Road
Rugby

Postcode: CV239SS

Appliance Details

CO/CO2
Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.34 %

CO Reading:

93 ppm

Boiler Make:

Worcester

Boiler Model:

Zwb 32

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

Ventilation Size/H-L

Water/Fuel - Sound

Electrically Fused

Correct Valving Arrangement

Isolation Available - Electrical/Fuel (Within 1 metre)

Boiler/Plant room Clean & Clear

Service Checks

Satisfactory

Heat Exchanger

Ignition

Gas Valve

Fan

NA

Safety Device

NA

Control Box

Burner & Pilot

Fuel Pressure & Type

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

replaced gas valve and spark electrodes

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

12:50 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

12:50 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Mon-09-Nov-2020

Report Received By

Name:

Signature:

Date:

Mon-09-Nov-2020