



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

Southcrest Lodge Pool Bank Redditch

Certificate No Southcrest Lodge Pool Bank Redditch

Installation Details

Installation
Address:Brendan Scott
Southcrest Lodge
Pool Bank
Redditch

Postcode: B97 4JS

Client Details

Client
Address:Brendan Scott
Southcrest Lodge
Pool Bank
Redditch

Postcode: B97 4JS

Appliance Details

CO/CO2
Ratio:

0.0009

Service: 0.0009

Breakdown:

N/A

CO2

Reading:

8.76 %

CO Reading:

83 ppm

Boiler Make:

Baxi

Boiler Model:

Duo tec 33 HEA GC no 47-075

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

Ignition

Gas Valve

Fan

NA

Safety Device

YES

Control Box

Burner & Pilot

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

flue not sealed, incorrect fuse in plug, cleaned filter and condense. max co 83 co2 8.76 ratio 0.0009 min co 10 co2 8.03 ratio 0.0001 o2 20.8%

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

03:30 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

03:30 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Thu-10-Sep-2020

Report Received By

Name:

Signature:

Date:

Thu-10-Sep-2020