

Gas Service/Breakdown Record

Certificate Ref.

Flat 4 6 Warwick New Road-Mr Ran

Certificate No Flat 4 6 Warwick New

Installation Details

Installation Address: Flat 4 6 Warwick New Road
Flat 4 6 Warwick New Road
Flat 4 6 Warwick New Road
Postcode: CV32 5JF

Client Details

Client Address: Mr Ranjit Bhopal
10 Shallowford Grove
Milton Keynes
Postcode: MK4 1ND

Appliance Details

CO/CO2 Ratio: 0.0006 Service: YES Breakdown: N/A CO2 Reading: 10.14 % CO Reading: 60 ppm
Boiler Make: Glow worm Boiler Model: Flexicom 30sx Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean	YES			
Pilot Assembly Cleaned & Adjusted	YES			
Ignition System Cleaned & Adjusted	YES			
Burner Fan & Airways Cleaned	YES			
Heat Exchanger/Flueways Clean & Clear	YES			
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place	YES			

Additional Notes

full service, replaced burner chamber seal

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 10:45 am
Gas ID Number 4464997 Time of Departure: 10:45 am
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Fri-14-Aug-2020
Report Received By Name: Signature: Date: Fri-14-Aug-2020