



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

15 Wheathill Close

Certificate No 15 Wheathill Close

Installation Details

Installation
Address:Scott Dunlop
15 Wheathill Close
Leamington Spa

Postcode: CV32 6PL

Client Details

Client
Address:Scott Dunlop
15 Wheathill Close
Leamington Spa

Postcode: CV32 6PL

Appliance Details

CO/CO2
Ratio:

Service: YES

Breakdown: N/A

CO2
Reading:

%

CO Reading: ppm

Boiler Make:

Boiler Model:

Boiler Serial No:

Appliance Make:

Legend

Appliance Model:

Olympus

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

Service Checks

Satisfactory

Heat Exchanger

Ignition

YES

Gas Valve

YES

Fan

NA

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

YES

Pilot Assembly Cleaned & Adjusted

YES

Ignition System Cleaned & Adjusted

YES

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

Interlocks in Place

Additional Notes

gas fire service

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

09:23 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

09:23 am

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Tue-14-Jul-2020

Report Received By

Name:

Signature:

Date:

Tue-14-Jul-2020