

Gas Service/Breakdown Record

Certificate Ref.

16 Towers Close

Certificate No 16 Towers Close

Installation Details

Installation Address: Mrs A Johnson
16 Towers Close
Kenilworth
Postcode: CV8 1FG

Client Details

Client Address: Mrs A Johnson
16 Towers Close
Kenilworth
Postcode: CV8 1FG

Appliance Details

CO/CO2 Ratio: 0.0010 Service: YES Breakdown: N/A CO2 Reading: 8.94 % CO Reading: 89 ppm

Boiler Make: Worcester Boiler Model: Greenstar 28i Junior Boiler Serial No:
Appliance Make: Appliance Model: Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound	YES			
Interlocks in Place				

Additional Notes

served boiler and cleaning condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services
47 Alspath Road
Meriden
Postcode: CV7 7LU

Gas Safe Number 526645 Time of Arrival: 02:55 pm
Gas ID Number 4464997 Time of Departure: 02:55 pm
Telephone Number 07961768920

Report Issued By Name: Andrew King-Page Signature: Date: Tue-14-Jul-2020
Report Received By Name: Signature: Date: Tue-14-Jul-2020