



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

6 Hampdon Way 2

Certificate No 6 Hampdon Way 2

Installation Details

Installation
Address:Mr C Whyte
6 Hampdon way
Wellesbourne

Postcode: CV35 9NX

Client Details

Client
Address:Mr C Whyte
6 Hampdon way
Wellesbourne

Postcode: CV35 9NX

Appliance Details

CO/CO2
Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2

Reading:

%

CO Reading:

ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 32CDi Comp

Boiler Serial No:

55707200000397733600

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

Boiler service completed

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

09:30 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

09:30 am

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Wed-29-Apr-2020

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Wed-29-Apr-2020