



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

52 Wilsons lane Longford Coventry

Certificate No 52 Wilsons lane Longf

Installation Details

Installation
Address:Daniel Stevens
52 Wilson's lane
Longford
Coventry

Postcode: CV6 6AD

Client Details

Client
Address:Daniel Stevens
52 Wilson's lane
Longford
Coventry

Postcode: CV6 6AD

Appliance Details

CO/CO2
Ratio:

0.0010

Service:

YES

Breakdown:

YES

CO2

Reading:

98 %

CO Reading:

9.83 ppm

Boiler Make:

Main

Boiler Model:

main combi 25 eco

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

replaced prv, recharged expansion vessel and serviced boiler

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

12:13 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

12:13 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Wed-19-Feb-2020

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Wed-19-Feb-2020