



# Gas Service/Breakdown Record

Certificate Ref.

2 Hicks Close

Certificate No 2 Hicks Close

## Installation Details

Installation Address:

Mr C Beesley  
2 Hicks Close  
Woodloes Park  
Warwick

Postcode: CV34 5ND

## Client Details

Client Address:

Mr C Beesley  
2 Hicks Close  
Woodloes Park  
Warwick

Postcode: CV34 5ND

## Appliance Details

CO/CO2 Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2 Reading:

97 %

CO Reading:

9.78 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 30Si

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

## Preliminary Checks

### Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

## Service Checks

### Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

## Service Operations

### Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

## Additional Notes

replaced prv, cleaned expansion vessel hose, recharged expansion vessel and serviced boiler

## Spares Required

none

## Engineers Details

Trading Title:

Coventry Gas Services  
47 Alspath Road  
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

12:30 pm

Gas ID Number

4464997

Time of Departure:

12:30 pm

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Fri-14-Feb-2020

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Fri-14-Feb-2020