



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

171 Lutterworth Road Nuneaton CV

Certificate No 171 Lutterworth Road

Installation Details

Installation
Address:Gurminder Johal
171 Lutterworth Road
Nuneaton

Postcode: CV11 6PY

Client Details

Client
Address:Gurminder Johal
171 Lutterworth Road
Nuneaton

Postcode: CV11 6PY

Appliance Details

CO/CO2
Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.83 %

CO Reading:

98 ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar Highflow 440 GC

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

YES

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

YES

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

replaced filling loop, non return valve, pressure relief valve and serviced boiler

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

02:08 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

02:08 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Thu-23-Jan-2020

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Thu-23-Jan-2020