

Gas Service/Breakdown Record

Certificate Ref.

1 Leese Drive Solihull B90 4LQ

Certificate No 1 Leese Drive Solihull

Installation Details

Installation Address: Chris Moore
1 Leese Drive
Solihull

Postcode: B90 4LQ

Client Details

Client Address: Chris Moore
1 Leese Drive
Solihull

Postcode: B90 4LQ

Appliance Details

CO/CO2 Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2 Reading:

9.83 %

CO Reading:

98 ppm

Boiler Make: Ideal

Boiler Model: LOGIC SYSTEM 18

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks	Satisfactory	YES	NO	NA
Flue:Atmospheric/Fan assisted/Fan Dilution	YES			
Ventilation Size/H-L	YES			
Water/Fuel - Sound	YES			
Electrically Fused	YES			
Correct Valving Arrangement	YES			
Isolation Available - Electrical/Fuel (Within 1 metre)	YES			
Boiler/Plant room Clean & Clear	YES			
Service Checks	Satisfactory	YES	NO	NA
Heat Exchanger	YES			
Ignition	YES			
Gas Valve	YES			
Fan	YES			
Safety Device	YES			
Control Box	YES			
Burner & Pilot	YES			
Fuel Pressure & Type	YES			
Service Operations	Satisfactory	YES	NO	NA
Burner Washed & Clean				
Pilot Assembly Cleaned & Adjusted				
Ignition System Cleaned & Adjusted				
Burner Fan & Airways Cleaned				
Heat Exchanger/Flueways Clean & Clear				NA
Fuel & Electrical Supply Connected & Sound				
Interlocks in Place				

Additional Notes

cleaned condense trap

Spares Required

none

Engineers Details

Trading Title: Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of Arrival:

10:37 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

10:37 am

Report Issued By Name: Andrew King-Page

Signature:

Date: Mon-13-Jan-2020

Report Received By Name: Andrew King-Page

Signature:

Date: Mon-13-Jan-2020