



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

33a Jobs Lane Coventry CV4 9DZ

Certificate No 33a Jobs Lane Coven

Installation Details

Installation
Address:Kevin Brown
33a Jobs Lane Coventry CV4 9DZ
Coventry

Postcode: CV4 9DZ

Client Details

Client
Address:Kevin Brown
33a Jobs Lane Coventry CV4 9DZ
Coventry

Postcode: CV4 9DZ

Appliance Details

CO/CO2
Ratio:

0.0007

Service:

YES

Breakdown:

YES

CO2

Reading:

%

CO Reading:

ppm

Boiler Make:

Worcester

Boiler Model:

Greenstar 30 Si

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

YES

Pilot Assembly Cleaned & Adjusted

YES

Ignition System Cleaned & Adjusted

YES

Burner Fan & Airways Cleaned

YES

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

replaced auto air vent, flue way seal, cleaned filter and condense trap,
sealed leak on condense trap

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

11:26 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

11:26 am

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Wed-20-Nov-2019

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Wed-20-Nov-2019