



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

9 Binley Avenue Coventry CV3 2EE

Certificate No 9 Binley Avenue Cove

Installation Details

Installation
Address:Kaia Bickley
9 Binley Avenue
Coventry

Postcode: CV3 2EE

Client Details

Client
Address:Kaia Bickley
9 Binley Avenue
Coventry

Postcode: CV3 2EE

Appliance Details

CO/CO2
Ratio:

0.0010

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.87 %

CO Reading:

98 ppm

Boiler Make:

Vokera

Boiler Model:

Vision C

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

YES

Pilot Assembly Cleaned & Adjusted

YES

Ignition System Cleaned & Adjusted

YES

Burner Fan & Airways Cleaned

YES

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

01:45 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

01:45 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Fri-15-Nov-2019

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Fri-15-Nov-2019