



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

15 Wadbarn S

Certificate No 15 Wadbarn S

Installation Details

Installation
Address:The Tenant
15 Wadbarn
Dickens Heath
Solihull

Postcode: B90 1ST

Client Details

Client
Address:Black And Golds Estate Agents
117 Stratford Rd
Shirley
Solihull

Postcode: B90 3ND

Appliance Details

CO/CO2
Ratio:

Service: YES

Breakdown: N/A

CO2
Reading:

%

CO Reading:

ppm

Boiler Make: Potterton

Boiler Model: SUPRIMA 40

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

YES

Pilot Assembly Cleaned & Adjusted

YES

Ignition System Cleaned & Adjusted

YES

Burner Fan & Airways Cleaned

YES

Heat Exchanger/Flueways Clean & Clear

YES

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

boiler showing wear and tear

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

11:10 am

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

11:10 am

Report Issued By

Name: Andrew King-Page

Signature:

Date:

Fri-11-Oct-2019

Report Received By

Name: Andrew King-Page

Signature:

Date:

Fri-11-Oct-2019