



West Lothian Gas



Gas Service/Breakdown Record

Certificate Ref.

15 Ladbroke Road

Certificate No 15 Ladbroke Rd

Installation Details

Installation
Address:15 Ladbroke road
15 Ladbroke road
Bishops Itchington
Warwickshire

Postcode: CV47 2RA

Client Details

Client
Address:Heather Dore
70 Marlborough Drive
Leamington Spa

Postcode: CV31 1GW

Appliance Details

CO/CO2
Ratio:

Service: YES

Breakdown: YES

CO2
Reading:

9.3 %

CO Reading: 74 ppm

Boiler Make:

Vaillant

Boiler Model:

ECOMAX pro 28 E VU 286-0

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

YES

Ignition System Cleaned & Adjusted

YES

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

boiler filling loop replaced, pressure relief replaced, expansion vessel replaced

Spares Required

all supplied

Engineers Details

Trading Title:

Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

526645

Time of
Arrival:

04:11 pm

Gas ID Number

4464997

Time of

Telephone Number

07961768920

Departure:

04:11 pm

Report Issued By

Name:

Andrew King-Page

Signature:

Date:

Tue-06-Aug-2019

Report Received By

Name:

Andrew King-Page

Signature:

Date:

Tue-06-Aug-2019