

Gas Service/Breakdown Record

Certificate Ref.

66 Kingsley Road

Certificate No 66 Kingsley Roa

Installation Details

Installation Address: Kim Annetts
66 Kingsley Road
Bishops Tachbrook

Postcode: CV33 9RR

Client Details

Client Address: Kim Annetts
66 Kingsley Road
Bishops Tachbrook

Postcode: CV33 9RR

Appliance Details

CO/CO2 Ratio:

Service: YES

Breakdown: N/A

CO2 Reading: 92.45 %

CO Reading: 91 ppm

Boiler Make: Worcester

Boiler Model: Greenstar 30i Erp

Boiler Serial No: 55708600016057733600

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks

Satisfactory

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

Service Checks

Satisfactory

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations

Satisfactory

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

Interlocks in Place

Additional Notes

Boiler commission

Spares Required

Engineers Details

Trading Title: Coventry Gas Services
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number 526645

Time of Arrival: 05:45 pm

Gas ID Number 4464997

Time of Departure: 05:45 pm

Telephone Number 07961768920

Report Issued By Name: Andrew King-Page

Signature:

Date: Wed-01-May-2019

Report Received By Name: Andrew King-Page

Signature:

Date: Wed-01-May-2019